



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

I.

RF-a/b. RF-6HA & RF-8HA Series

NI/II/2/ABCD/T6 Ta = +54 °C; T5 Ta = +65 °C; T4A Ta = +85 °C

NI/II/2/IIC/T6 Ta = +54 °C; T5 Ta = +65 °C

a = PCB Type: 6HA or 8HA

b = LED Array: 1x4, 1x6 or 3x4

	<i>LED Flasher</i>	<i>Feature</i>	<i>Input</i>	<i>Regulated In</i>	<i>LEDs</i>
(1)	8084-0018G,W,Y,R,B, (RF6/1X4)	RS-232/RS-485	10-30 VDC	6.4 W (avg.)	4-Place
(2)	8084-0018GP,WP,YP,RP,BP, (RF6/1X4)	RS-232/RS-485	10-30 VDC	6.4 W (avg.)	4-Place
(3)	8084-0020B,G,R,Y,W, (RF6/3X4)	RS-232/RS-485	10-30 VDC	6.4 W (avg.)	12-Place
(4)	8084-0020BP,GP,RP,YP,WP, (RF6/3X4)	RS-232/RS-485	10-30 VDC	6.4 W (avg.)	12-Place
(5)	8084-0024B,G,R,Y,W, (RF8/3X4)	RS-232/RS-485	10-30 VDC	6.4 W (avg.)	12-Place
(6)	8084-0024BP,GP,RP,YP,WP, (RF8/3X4)	RS-232/RS-485	10-30 VDC	6.4 W (avg.)	12-Place
(7)	8084-0025G,W,Y,R,B, (RF8/1X4)	RS-232/RS-485	10-30 VDC	6.4 W (avg.)	4-Place
(8)	8084-0025GP,WP,YP,RP,BP, (RF8/1X4)	RS-232/RS-485	10-30 VDC	6.4 W (avg.)	4-Place